



Lars Christensen

Version: 1
Sagsnr:
Rekv. nr:
Genereret: 01.12.2023
Bilag:

Analyseparameter	Resultat	Min	Max	Udenfor	D.L.	Metode/Reference	+/-
Temperatur	9.0 °C	-	-		0.1	TERMOMETER	10%
pH	7.7 pH	7	8.5		0.05	M-0010 DS/EN/ISO 10523:2012	10%
Aggressiv CO2	<2 mg/L	-	2		2	M-0004 DS 236	10%
Bicarbonat HCO3	171 mg/L	-	-		0.5	M-0006 DS 256	10%
Methan	<0.01 mg/L	-	0.01		0.01	#HS-GC-FID DANAK 361	20%
Svovlbrinte	<0.01 mg/L	-	0.01		0.01	M-0098 DS 278:1976	10%
Nitrit	<0.001 mg/L	-	0.01		0.001	M-0015 DS 222	10%

Der er ikke fundet resultater uden for de anførte min- og maxgrænser.

Nørresundby d. 01.12.2023

Annette Christensen
Annette Christensen, laborant

SGS Analytics Denmark A/B Bøgildsmindevej 21, 9400 Nørresundby, Danmark DK20228806 +45 98 19 39 00 www.sgs.com/analytics-dk